

# INSTALLATION INSTRUCTIONS

Read installation instructions first before installing.  
Check parts to ensure that no damage has occurred during transit and that no parts are missing.

## Alpha™ Coupling

### Two-Bolt Wide Range Restraint Coupling for 8" - 12" Pipe Sizes

**ALPHA IS APPROVED FOR USE ON:**

- ✓ Ductile Iron
- ✓ Cast Iron (Classes A, B, C and D)  
Provided it conforms to diameter and roundness spec.
- ✓ PVC, IPS size (Sch 40, Sch 80 and SDR 21)
- ✓ PVC, C900
- ✓ PVC, C909 (MWCO)
- ✓ HDPE: SDR 9, 11, 13.5 and 17. No stiffeners required.  
See HDPE pipe precautions on reverse.
- ✓ HDPE: For SDRs greater than 17, pipe stiffeners are required. See HDPE pipe precautions on reverse.

For other SDR's and pipe materials contact Romac.

**ALPHA RANGES**

**STANDARD ALPHA:** For IPS through DI pipe diameters.

**ALPHA XL:** For DI through Oversize Cast pipe diameters.


SIZE	STANDARD ALPHA	ALPHA XL
8"	8.60 - 9.10	9.05 - 9.40
10"	10.75 - 11.20	11.10 - 11.45
12"	12.75 - 13.30	13.20 - 13.60

**Step 1** • Measure pipe diameter and verify with the ranges listed above to ensure the correct size coupling has been selected.


**Step 2** • Remove any scale or debris that could interfere with gripper engagement of the pipe. Clean the pipe surfaces wherever the gaskets will come in contact with the pipe, and check to see that the pipe surface is smooth (no dents, projections, gouges, etc.) where the gaskets seal against the pipe.

**Step 3** • Lubricate the gasket and pipe surface with a suitable gasket lubricant.

**Step 4** • With the bolts in the extended position, place the coupling onto one pipe end. Bring the other pipe into position and slide coupling over the gap.




There should be a minimum of 4" of pipe insertion per coupling end. Confirm proper alignment between pipes and maintain the recommended minimum gap between pipe ends (1/4" - 1/2").



For installation on HDPE, pipe ends should be butted against each other.

**Step 5** • Set the desired pipe deflection angle.




**Std. Alpha & Alpha XL**  
Maximum deflection:  
4° on each end

**Alpha XL installations at the top of the range**  
Maximum deflection:  
2° on each end

**Note:** Do not deflect pipe joint after installation.

**Step 6** • With the coupling properly located, tighten the nuts to 45 ft-lbs using a torque wrench.

**NOTE:** Do not use an impact wrench. Do not overtorque, or retighten. If a good seal is not achieved at 45 ft-lbs of torque, refer to the Common Installation Problem listed on side two.



**Step 7** • Confirm proper installation by pressurizing the line and checking for leaks.

**Step 8** • Backfill and compact carefully around pipe and coupling.



# INSTALLATION INSTRUCTIONS

## Alpha™ Coupling Two-Bolt Wide Range Restraint Coupling for 8" - 12" Pipe Sizes

### PRECAUTIONS

1. Check diameter of pipe to make sure the correct sized coupling has been selected.
2. Confirm the pipe is round. The coupling may not fit or function on pipe that is too far out of round.
3. Clean pipe to remove dirt and corrosion from pipe surface. Use appropriate scale removal tools where appropriate to assure all scale and debris is properly removed.
4. Lubrication and additional cleaning should be provided by brushing both the gasket and plain pipe end with soapy water or approved pipe lubricant per ANSI/AWWA C111/A21.11.
5. Make sure no foreign materials lodge between gasket and pipe, between the grippers or in the end ring mechanism.
6. Avoid loose fitting wrenches, or wrenches too short to achieve proper torque.
7. Keep threads free of foreign material to allow proper tightening.
8. For cold weather conditions (below 40° F), performance can be improved by warming up the coupling and gasket.
9. Verify that the grippers are in contact with the pipe surface.
10. Do not strike or pry on the coupling with hammers, shovels or other equipment.
11. When reinstalling, prior to pressure application, be sure to inspect all parts for damage and apply additional lubricant to the fasteners.
12. If it's necessary to remove Alpha, loosen the bolt and tap the end ring bolt receiver open. Tapping the hooks into their notches may also be required.
13. Do not reuse coupling after pressure application.
14. It is common for the bolt receivers to meet on installations at the bottom of the range.
15. Directional drilling requires special consideration prior to installation. Contact Romac Engineering for any directional drilling applications.
16. Romac mechanical restraint products are designed and tested to provide axial load restraint as specified. System design must be such that the restraint is only exposed to this type of loading. Special consideration may be required for above ground installations where the alignment and support benefits of earth are not present.

### PRECAUTIONS FOR HDPE PIPE

1. Pipe ends should be butted against each other.
2. For SDRs greater than 17, pipe stiffeners are required.
3. Alpha working pressure not to exceed pressure rating of pipe.
4. Operating temperatures are limited to 85° F maximum and 32° F minimum.
5. Recommended for buried applications only. For above ground use, contact Romac Engineering.

### COMMON INSTALLATION PROBLEMS

1. Pipe not inserted into the coupling far enough.
2. Too much pipe deflection.
3. Damage to the outer pipe surface (dents, projections, gouges, etc.)
4. Bolts not tightened to proper torque.