

SL1 & SL2 PIPE REPAIR CLAMP WITH REMOVEABLE BOLTS

SUBMITTAL INFORMATION



SL1

NSF61/372 Certified upon request.

MATERIALS

SHELL

304 Stainless Steel 22 or 20 gauge depending on size.

SIDEBARS

Heavy gauge 304 Stainless Steel, GTAW welded to form permanent fusion with shell.

LUGS

3/16" 304 Stainless Steel, fused to sidebars by GMAW welding.

BOLTS

5/8"-11 UNC thread track head, type 304 stainless steel per ASTM A 193.

NUTS

5/8" heavy hex, type 304 Stainless Steel per ASTM A 194. Nuts coated to prevent galling.

ARMORS

Heavy gauge 304 Stainless Steel, bonded to gasket to bridge gap at lug area.

GASKETS

Virgin SBR rubber compounded for water and sewer service in accordance with ASTM D 2000 MAA 610. Other compounds available for petroleum or high temperature service, or other special applications.

WELDS

GMAW and GTAW welds. 308L Stainless Steel filler wire used as appropriate. All welds fully passivated for enhanced corrosion resistance.

STANDARD

Complies with ANSI/AWWA Standard C230 Stainless-Steel Full-encirclement Repair and Service Connection Clamps 2" – 12".

SIZES & RANGES

See catalog.

12/3/2024

Document # 10-8-0016

This information is based on the best data available at the date printed above. Please check with Romac Engineering Department for any updates or changes.



www.romac.com
21919 20th Avenue SE • Suite 100 • Bothell, WA 98021
Phone (425) 951-6200 • 1-800-426-9341 • Fax (425) 951-6201