

# DJ400 DISMANTLING JOINT 14" - 72" CLASS "E" FLANGE

## SUBMITTAL INFORMATION



## MATERIALS

### FLANGED SPOOL

AWWA C207 Class E Steel Ring Flange, compatible with ANSI Class 125 and 150 bolt circles. Pipe is ASTM A36 plate 1% cold expanded to size.

### END RING AND BODY

The end ring and body are made from ASTM A36 steel.

### GASKETS

NBR Compounded for water and sewer service meeting the requirements of ASTM D 2000. Other compounds available on request.

### BOLTS AND NUTS

ASTM A588 HSLA bolt material. Stainless Steel, Types 304 or 316 is optional.

### TIE RODS

High tensile steel per ASTM A193 grade B7, nuts ASTM A 194 grade 2H. Stainless steel, type 304 or 316 is optional.

### COATINGS

Fusion bonded epoxy, NSF 61 certified. All surfaces are coated, including flange faces.

## PRESSURE

When properly installed on a pipe that is within the coupling manufacturer's tolerances, Romac style DJ400 can work at pressures up to the maximum rating of the flange. AWWA Class E flanges are rated for 275 psi. Higher working pressures can be accommodated. Consult your representative.

## ASSEMBLY TOLERANCE

Three inches flange face to flange face. For a different length, contact Romac Engineering.

## SIZE

14"-72". See drawing B2127-A for details. Sizes up to Ø170" are available.

## STANDARD

The Romac DJ400 meet all specifications set forth in the AWWA C219 Standard.

11/17

Document # 20-8-0030

*This information is based on the best data available at the date printed above. Please check with Romac for any updates or changes.*