

400RG-PVC RESTRAINED COUPLING FOR AWWA C900 12" & C905 14"-24" PVC PIPE

SUBMITTAL INFORMATION



MATERIALS

BODY

Made from ASTM A 36 steel.

RESTRAINT GLAND

Ductile (nodular) iron, meeting or exceeding ASTM A 536, Grade 65-45-12. Romac's RomaGrip for PVC is used as the glands, see RomaGrip for PVC Submittal for technical information.

GASKETS

MJ, gaskets are made from rubber compounded for water and sewer service in accordance with ASTM D 2000

MBA810Z. Other compounds are available for petroleum, chemical, or high temperature service.

BOLTS AND NUTS

ASTM A 193 Grade B7 all-thread-rod. Nuts per ASTM A 194 Grade 2H. Type 304 and 316 Stainless Steel bolt material optional.

COATINGS

Shop coat applied to parts for corrosion protection in transit. Fusion bonded epoxy, RomaGrip Romabond polyester, liquid epoxy and other coatings available on request.

PRESSURE

For pressure rating see Romac PVC RomaGrip submittal information.

SIZES

12 inch through 24 inch.

This information is based on the best data available at the date printed above. Please check with Romac for any updates or changes.